

PROFORMA REGARDING SAFE DRINKING WATER AND SANITARY CONDITION
CERTIFICATE.

No. 4/25Date : 9/7/2025

It is certified that an inspection team headed by Dr. Sabeer B JHI Groj (Name of Officers with designation) from FHE Kadammanitta (Name of Department/Office) inspected the 30/6/2025 Savio English School, Naranganam (Name & Address of the School) on _____ and found that the _____ (Name of school) has safe drinking water facilities for the students and members of staff of the institution and is maintaining the hygienic sanitation condition in the school building & the campus as per the norms prescribed by the Central/State/U.T Govt.

The above valid for a period of 2025-2026.Signature with Seal : [Signature]Name : Sabeer BDesignation : JHI Groj H/C

To

THE MANAGER

SAVIO ENGLISH SCHOOL, NARANGANAM WEST PO
KOZHENCHERRY, PATTANAMTHITTA.

(Name & Address of the Institution)

[Signature][Signature]



ഭരണഭാഷ-മാതൃഭാഷ

ജില്ലാ ഫുഡ് ടെസ്റ്റിംഗ് ലബോറട്ടറി

കുടുംബ സുരക്ഷാ വകുപ്പ്, കേരള സർക്കാർ

പോലീസ് സ്റ്റേഷൻ എതിർവശം, അഴുർ റോഡ്, പത്തനംതിട്ട -689 645
Telephone No.8606909352, E-mail -dftlpta@gmail.com

Test Report

Sample Ref No.2596B, 2597C				Report No: WA(P) 741/2025		
Issued to : Savio English School Naranganam West P O Kozhencherry PTA				Report date :03.07.2025		
Sampled Description		Water		Received on	30.06.2025	
Sample drawn by/ Date		Customer/30.06.2025		Analysis started on	30.06.2025	
Customer's reference				Analysis completed on	03.07.2025	
Sample source		Well water		Source location		
Sl no (1)	Test parameters (2)	Units (3)	Results (4)	As per IS 10500:2012 including Amd nos 1,2,3 & 4 (5)		Test method (6) FSSAI Manual of methods of analysis of foods, Water-2016
				Requirement (acceptable limit)	Permissible limit in the absence of alternate source	
Organoleptic and Physical parameters						
01.	Appearance	-	Clear	Clear	Clear	-
02.	Colour	-	Colourless	Colourless	Colourless	-
03.	Odour	-	Agreeable	Agreeable	Agreeable	P-15
04.	Turbidity	NTU	0.01	1	5	P-26
05.	Electrical conductivity	µS	57.3	-	-	-
06.	pH		6.56	6.5-8.5	6.5-8.5	P-17
07.	Total Dissolved Solids	mg/l	28.6	500	2000	P-29
General Chemical parameters						
08.	Total hardness (as CaCO ₃)	mg/l	16.0	200	600	P-99
09.	Iron (as Fe)	mg/l	0.1	1.0	1.0	-
10.	Total Alkalinity (as CaCO ₃)	mg/l	16.0	200	600	P-104
11.	Chloride (as Cl)	mg/l	16.0	250	1000	P-76
12.	Sulphate (as SO ₄)	mg/l	Nil	200	400	P-107
13.	Nitrate(as NO ₃)	mg/l	Nil	45	45	P-68
14.	Ammonia (as Total ammonia-N)	mg/l	Nil	0.5	0.5	P-39
Bacteriological Parameters						
15.	Bacteriological analysis	Result		Requirement		IS 1622 – 1981 Reaffirmed 2019
		Less than 2 mpn/100 ml		Less than 2 mpn/100 ml		

Opinion: കെമിക്കൽ & ബാക്റ്റീരിയോളജിക്കൽ അനാലിസിസ് തൃപ്തികരം

Pathanamthitta

03.07.2025

Note: 1. The test report relates to the tested parameters only

2. The test report related only to the tested item as received

3. The report shall not be reproduced except in full or part without approval of the laboratory

4. Unless informed by customer the test items will not be retained for more than 10 days from the date of issue of report



Jombal P

RESEARCH OFFICER

സർവ്വ ഓഫീസർ
ജില്ലാ കുടുംബശ്രീ ഡയറക്ടറുടെ അധീനതയിൽ
പത്തനംതിട്ട

*****end of report*****