APPENDIX - VIII

PROFORMA REGARDING SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE.

No. 5/26 Date : 8/6/2026

It is certified that an inspection team headed by Sabeer.B IHI Grd.I HI i/c (Name of Officers with designation) from FHC Kadammanitta (Name of Department/Office) inspected the 4/6/2026 Savio English School, Naranganam (Name & Address of the School) on _____ and found that the _____ (Name of school) has safe drinking water facilities for the students and members of staff of the institution and is maintaining the hygienic sanitation condition in the school building & the campus as per the norms prescribed by the Central/State/U.T Govt.

The above valid for a period of 2026-2027

Signature with Seal : Sabeer

Name : Sabeer.B

Designation : IHI Grd HI i/c

OFFICE OF THE FAMILY HEALTH CENTRE ★ KADAMMANITTA ★

To

The Manager
Savio English School
Naranganam, Kozhenchery

(Name & Address of the Institution)

ഭരണഭാഷ മാതൃഭാഷ

ജില്ല ഭക്ഷ്യ പരിശോധന ലബോറട്ടറി

ഭക്ഷ്യ സുരക്ഷാ വകുപ്പ്, കേരള സർക്കാർ
അണ്ണായിപ്പാറ,വെട്ടിപ്പുറം,കടമ്മനിട്ട റോഡ്,പത്തനംതിട്ട-689 645DIGIPIN: MCT PM6264J
ഫോൺനം.8606909352, ഇ-മെയിൽ–dftlpta@gmail.com

Test Report

Sample Ref No.1717 B & C				Report No:**WA(P) 566/2026**		
Issued to: **Manager, Savio English School, Naranganam West, PTA**				Report date: 04.06.2026		
Sample Description		Water		Received on		25.05.2026
Sample drawn by/ Date		Customer/25.05.2026		Analysis started on		25.05.2026
Customer's reference				Analysis completed on		04.06.2026
Sample source		Well		Source location		
Sl no (1)	**Test parameters (2)**	**Units (3)**	**Results (4)**	**As per IS 10500:2012 including Amd nos 1,2,3 & 4 (5)**		**Test method (6) FSSAI Manual of methods of analysis of foods, Water-2016**
				Requirement (acceptable limit)	**Permissible limit in the absence of alternate source**	
Organoleptic and Physical parameters						
01.	Appearance	-	Clear	Clear	Clear	-
02.	Colour	-	Colourless	Colourless	Colourless	-
03.	Odour	-	Agreeable	Agreeable	Agreeable	P-15
04.	Turbidity	NTU	0.03	1	5	P-26
05.	Electrical conductivity	mS	78.3	-	-	-
06.	*p*H		**5.02**	6.5-8.5	6.5-8.5	P-17
07.	Total Dissolved Solids,Max	ppm	39.1	500	2000	P-29
General Chemical parameters						
08.	Total hardness (as $CaCO_3$), Max	mg/l	24.69	200	600	P-99
09.	Iron (as Fe),Max	mg/l	0.1	1.0	1.0	-
10.	Calcium(as Ca),Max	mg/l	6.59	75	200	P-144
11.	Magnesium(as Mg),Max	mg/l	2.0	30	100	P-85
12.	Total Alkalinity (as $CaCO_3$),Max	mg/l	10.0	200	600	P-104
13.	Chloride (as Cl),Max	mg/l	13.19	250	1000	P-76
14.	Sulphate (as SO_4),Max	mg/l	Nil	200	400	P-107
15.	Nitrate (as NO_3),Max	mg/l	Nil	45	45	P-68
16.	Ammonia (as Total ammonia-N),Max	mg/l	Nil	0.5	0.5	P-39

Bacteriological Parameters

Sl no	**Test parameters**	**Result**	**Requirement**	**Test method**
01.	Coliforms	Less than 2 MPN/100 ml	Less than 2 MPN/100 ml	IS 1622 – 1981 Reaffirmed 2019
02.	*E.*Coli	Absent /100 ml	Absent/100 ml	

Opinion:

Government Analyst

Pathanamthitta
04.06.2026

Note: 1. The test report relates to the tested parameters only
2. The test report related only to the tested item as received
3. The report shall not be reproduced except in full or part without approval of the laboratory.
4. Unless informed by customer the test items will not be retained for more than 10 days from the date of issue of report

Government Analyst
Dist. Food Testing Lab (DFTL)
Pathanamthitta - 689645